

DIRECTORATE OF FIRE SERVICES HIMACHAL PRADESH SHIMLA-2  
No. HOM(FS)(HQ)6-10/76-XL -Sml, NOC dated Shimla-2

TO WHOM IT MAY CONCERN

12/4/2018


That the premises of D.A.V Sr. Sec. Public School Baghni, Tehsil Nurpur, Distt. Kangra was inspected on 20-02-2018 with reference to his application No. Nil dated Nil by the Incharge, Fire Post Nurpur with regard to measures adopted for protection against fire and it has been reported/ recommended.

That the First Aid Fire Fighting measures adopted by the above applicant in school were found satisfactory at the time of inspection. Hence No Objection Certificate is issued/ renewed for the two years (i.e.10-04-2018 to 09-04-2020) subject to fulfillment of the following conditions:-

1. That each individual working on the above premises must be trained to handle/operate fire fighting equipment/system installed therein.
2. That it shall be the responsibility of the above named applicant to maintain the fire fighting equipment/system in perfect running condition, failing which this certificate shall be treated as cancelled.
3. Mock Drills shall be conducted in accordance with fire safety plan atleast once in every three months and written record shall be kept in the premises for the inspection of fire service.

Remarks: Adequate Fire precautionary measures be adopted in consultation with local Fire Officer during annual day function or any other function in the school where temporary structures and Pandals are to be erected.

To,  
The Principal,  
D.A.V Sr. Sec. Public School Baghni,  
Tehsil Nurpur, Distt. Kangra H.P.

  
Chief Fire Officer,  
Himachal Pradesh Shimla-2 11/4-18