

FIRE SAFETY CERTIFICATE

No. 05

Dated: 27/06/2023

Certified that the **DAV Public School, NTPC/TTPS at Talcher Thermal, Talcher , Angul, Odisha** comprised of **Old & New** basement (s) and **Old & New** (upper floors) owned/ occupied by **DAV Public School, NTPC/TTPS** have complied with the fire prevention and fire safety requirements in accordance with rule of State/ UT Fire Service Rules, and verified by the officers concerned of Fire Service on **15.05.2023** in the presence of **Mrs Tapaswini Mishra, Principal-cum-Member Secretary** and that the building/ premises is fit for occupancy upto classes **LKG to XII** with effect from **04.04.2023** for a period of **2year** in accordance with rule and subject to compliance of specific conditions as appended:-

1. Administrative Area	G. Floor	01- 5 kgs
2. Examination Section	G. Floor	01- 5 kgs
3. Book Section	G. Floor	01-12 kgs
4. Activity Hall	G. Floor	02- 5 kgs
5. Chemistry Laboratory	G. Floor	02- 5 kgs
6. Biology Laboratory	G. Floor	02- 5 kgs
7. Physics Laboratory	1 st Floor	02- 5 kgs
8. Computer Laboratory (Sr)	1 st Floor	02- 5 kgs
9. Computer Laboratory (Jr)	1 st Floor	02- 5 kgs
10. Library	1 st Floor	02- 5 kgs

Issued on **24.04.2023** (date of issue) at **DAV Public School, NTPC/TTPS** by **NTPC**

*Strike out whichever is not applicable.

Signature with Seal:

Name

Designation

To

Name & Address of Department/ Office:

**DAV Public School, NTPC/TTPS
Talcher Thermal, Talcher ,
Angul, Odisha**

**S. S. S. K. Mishra
Safety Officer
NTPC Limited Talcher Thermal**

ENDORSEMENT

The No Objection Certificate issued by Fire Service stand cancelled an annulled due to

(reasons to be recorded).

(Name and designation of the authorized signatory)

* The filled up certificate should be either in Hindi or English. If it is issued in vernacular language, translated notarized version in English be uploaded along with the original vernacular certificate as a single pdf.